

- \* If this distance is less than 5 feet the shaded area must be added to the water easement.
- \*\* If the easement length is over 25 feet it must be a minimum of 30 feet wide.
- \*\*\* All water easement lines around any fire hydrant must be straight with the side easement lines perpendicular to or parallel with the radial line from the & of the main easement.

DOCUMENT DATED SEC'Y FILE DOC.	<b>D</b> DENVER WATER
RIMS ITEM NO. CARD NO. DRN. ZYX IPM. ————————————————————————————————————	TYPICAL FIRE HYDRANT EASEMENT
	DATE: SEPTEMBER 1, 2004
SHEET 1 OF 1 SHEETS	SCALE: CAD

D.W.D. PROPERTY MANAGMENT STANDARDS. 10222004